



RIPPLEPAK

(division of Uthane Research LTD)
3115-14th ave., #6
Markham On L3R0H1
Ph: 905-940-2356



Insulapak for Basement

UL/ULC Certified for HVAC insulation
R10.6/inch

- Multilayered insulating gas bubble sheet laminated to metalized film
- RETROFIT
- R10.6 per inch
- Easy and safe install
- Unaffected by moisture mold/mildew
- Low cost
- 100% Recyclable
- PPE not required
- Uses: Wall cavity, HVAC duct and pipe wrap, concrete floor, Basement foundation
- UL/ULC certified meets ULC 25/50
- Built in vapour barrier



Basement Wall Cavity



Rolls - various depths & widths

Technical Data

Properties	Standards	Values
Thermal Resistance	ASTM C335	R10.6 per inch of thickness
Fire Rating	ASTM E84-13a	Flame Spread 0, Smoke 5
Emissivity	ASTM C1371	0.04
Reflectivity	ASTM E903	0.096
Water Vapor Transmission	ASTM E96	0.029 PERMS
Resistance to Fungus & Bacteria	ASTM C1338-08	Does not promote growth
Delamination or cracking	ASTM C1224-03	None
Operating Temperature Range	ASTM C411	-50° to 180°F
Temperature & Humidity Resistance	ASTM C1258	None, some metalized corrosion
Thermal Transmission Properties	ASTM C518-10	No thermal degradation noticed (250°F)



Foundation roll

